

Return address: P.O. box 337, 7500 AH Enschede, The Netherlands

Superior Manufacturing Group – Europe B.V.  
Att. Mrs. G. Dirckx  
Achterzeedijk 57  
2992 SB  
Barendrecht  
The Netherlands

TÜV Rheinland Nederland B.V.  
The Netherlands

Postal address:  
P.O. Box 337  
7500 AH Enschede

Parking and delivery:  
Josink Esweg 10  
7545 PN Enschede

[www.tuv.com/nl](http://www.tuv.com/nl)

T +31 88 888 7888  
F +31 88 888 7859

[Jaring.de.Wolff@nl.tuv.com](mailto:Jaring.de.Wolff@nl.tuv.com)

## **REPORT**

**Project number** : 89206690  
**Report number** : 89206690.01en

**Date**  
08-10-2014

**Project number**  
89206690

**Report number**  
89206690.01en

### **Received:**

A industrial mat, a floor covering, marked as: **"549 Safety Stance"**, size 1530 mm x 910 mm; TÜV-reference MT14-48336.01.

The samples have been received on 23-09-2014. The samples are selected by the applicant. The test house has had no influence on the sampling procedure.

**Phone number client**  
+31 180 643 115

### **Order:**

To determine the slip resistance according to DIN 51130, ramp test.  
The space of displacement is not determined.

**Fax number client**  
+31 180 611 551

### **Results:**

See page two.

**Article**  
549 Safety Stance

### **Appendix:**

None

**Appendix**  
-none-

TRN applies General Terms &  
Conditions which are filed at the office of  
the Clerk for civil affairs at the Court in  
Zutphen (the Netherlands) under number  
35/2010, dated November 17th 2010.

## RESULTS

### *Slip resistance*

Method DIN 51130:2013-5

Testing location : Subcontracted to an accredited laboratory.  
Date of testing : 30-09-2014

Mean angle of acceptance,  $\alpha_{ges}$  : 13.7°  
Slip resistance classification : R10\*

\* R10 requirement =  $10^\circ < \alpha_{ges} \leq 19^\circ$

Date  
08-10-2014

Project number  
89206690

Report number  
89206690.01en


Article  
549 Safety Stance

Page  
2/2

Author:  
Mr. J. de Wolff



Visa:  
Mr. R. Boerboom



*All rights reserved.*

*No part of this report may be reproduced, provided to and/or examined by third parties, and/or published by print, photoprint, microfilm, in electronic form or any other means without the explicit previous written consent of TÜV Rheinland Nederland B.V. The results are based upon the samples received and have not to be representative for the total production. Besides TÜV Rheinland Nederland B.V. had no influence on the sampling. In case this report was drafted within the context of an assignment to TÜV Rheinland Nederland B.V., the rights and obligations of contracting parties are subject to the General Terms & Conditions for Advisory, Research and Certification assignments to TÜV Rheinland Nederland B.V. and/or the relevant agreement concluded between the contracting parties.*

© 2010 TÜV Rheinland Nederland B.V.